




STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

6. Lighting/Foot-Candles

Repair light in female restroom 1004 (work order MB58812)

Remove peeling paint off ceiling and walls in the male locker room (work order MB 67203)

Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Inspection Conducted By: Naissa Julien (31113)

Phone: (305) 623-3500 ex. 24222

Received By: Signed

Date: 10/19/2015

Inspector Signature:

Client Signature: